

## HLSA12,5-320/3+1

- Lightning impulse current and surge arresters type T1+T2 ensure the equipotential bonding, eliminate the effects of lightning current and reduce switching, induced and residual overvoltage in single-phase and three-phase power supply systems.
- Suitable for objects with considerable levels of protection LPL III and LPL IV, such as small administration complexes, residential buildings, family houses or properties and halls without the incidence of persons and indoor equipment.
- Installed at the boundaries of LPZ 0 LPZ 1 and higher zones, closest to where overhead line enters the building i.e. in the main distribution boards.
- The products consist of varistors with big discharge ability.
- Configurations 1+1 and 3+1 are additionally combined with a gas discharge tube which ensures zero leakage current through the PE conductor.
- If the product contains two PE (or PEN) terminals, it must not be used as a PE (PEN) bridge.
- **S** indication specifies a version with remote monitoring.

Туре		HLSA12,5-320/3+1
Test class according to EN 61643-11:2012 (IEC 61643-11:2011)		T1, T2
System		TN-S, TT
Number of poles		4
Rated operating AC voltage	$U_N$	230 V
Maximum continuous operating voltage AC	U <sub>c</sub>	320 V
Maximum discharge current (8/20)	I <sub>max</sub>	50 kA
Impulse discharge current for class I test (10/350) L/N	l <sub>imp</sub>	12.5 kA
Charge (L/N)	Q	6.25 As
Specific energy for class I test (L/N)	W/R	39 kJ/Ω
Impulse discharge current for class I test (10/350) N/PE	l <sub>imp</sub>	50 kA
Charge (N/PE)	Q	25 As
Specific energy for class I test (N/PE)	W/R	625 kJ/Ω
Total discharge current (10/350) L1+L2+L3+N->PE	I <sub>Total</sub>	50 kA
Total discharge current (8/20) L1+L2+L3+N->PE	I <sub>Total</sub>	100 kA
Nominal discharge current for class II test (8/20) L/N	I <sub>n</sub>	20 kA
Nominal discharge current for class II test (8/20) N/PE	I <sub>n</sub>	50 kA
Open circuit voltage of the combination wave generator	U <sub>oc</sub>	6 kV
Voltage protection level at I <sub>n</sub> (L/N)	$U_p$	< 1.25 kV
Voltage protection level at I <sub>n</sub> (N/PE)	U <sub>p</sub>	< 1.3 kV
Temporary overvoltage test (TOV) for $t_T = 5 s (L/N)$	U <sub>T</sub>	387 V
Temporary overvoltage test (TOV) for $t_T = 0.2 \text{ s}$ (N/PE)	U <sub>T</sub>	1 200 V
Response time (L/N)	t <sub>A</sub>	< 25 ns
Response time (N/PE)	t <sub>A</sub>	< 100 ns
Maximal back-up fuse		160 A gL/gG
Short-circuit current rating at maximum back-up fuse	I <sub>sccr</sub>	60 kA <sub>rms</sub>
Lightning protection zone		LPZ 0-1, LPZ 1-2, LPZ 2-3

## **Lightning and surge arresters T1+T2**



using material gree of protection erating temperature  imum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022 esn't apply to "V" connection) for T1  imum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022 esn't apply to "V" connection) for T2	θ S	Polyamid PA6, UL94 V-0 IP20 -40 ÷ 70 °C 6 mm² (L, N) 16 mm² (PE, PEN) 2.5 mm² (L, N)
erating temperature imum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022 esn't apply to "V" connection) for T1 imum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022	S	-40 ÷ 70 °C 6 mm² (L, N) 16 mm² (PE, PEN)
nimum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022 esn't apply to "V" connection) for T1 nimum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022	S	6 mm² (L, N) 16 mm² (PE, PEN)
esn't apply to "V" connection) for T1  nimum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022		16 mm² (PE, PEN)
	S	2.5 mm <sup>2</sup> /I NI\
		2.5 mm <sup>-</sup> (L, N) 6 mm <sup>2</sup> (PE, PEN)
mp fastening range (solid conductor)		1.5 ÷ 25 mm <sup>2</sup>
mp fastening range (stranded conductor)		1.5 ÷ 16 mm <sup>2</sup>
htening moment		3 Nm
tallation		On DIN rail 35 mm
dular width		4 TE
erating position		Any
nalling at the device		Optic
portance of local signaling		OK – clear target FAULT – red target
mote signalling		No
dular design		No
etime		> 100 000 h
signed according to standards		
quirements and test methods for SPDs connected to low-voltage power systems		IEC 61643-11:2011
ety of Flammability of Plastic Materials		UL 94
plication standards		
tection against lightning		IEC 62305:2010
ection and erection of electrical equipment - Switchgear and controlgear		HD 60364-5-53:2022
ection and application principles for SPDs connected to low-voltage power systems		CLC/TS 61643-12:2009
dering, packaging and additional data		
SS	m	560 g
ss (including the packaging)	m	588 g
ckaging dimensions (H x W x D)		74 x 112 x 73 mm
ckaging value	V	0.61 dm <sup>3</sup>
M group		EG000021
M class		EC001457
stoms tariff no.		85363010
N code		8590681113592
. number		10 305




**The link in the QR code** leads to the online presentation of the **HLSA12,5-320/3+1**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com** 





## Application wiring diagram (installation)



## Internal diagram

