

HSA PV 1000/2 M

- Surge arresters type T2 intended for photovoltaic systems (PV) at U or Y connection.
- The advantage of the Y connection versus the U connection is the resistance to the earth connection of the working conductors and zero residual (leakage) current through the PE conductor.
- Particular varistor sectors, connected between the terminals L+, Land PE are equipped with internal disconnectors, which are activated when the varistors fail (overheat) and they are able to interrupt the DC current.
- Special construction of the internal disconnector allows installation without a back-up fuse.

- They are installed on the DC side in PV applications without an external LPS or with an external LPS, where the sufficient distance "s" is observed.
- Suitable for all LPL levels.
- Ensure the equipotential bonding of positive and negative busbars of PV systems and the elimination of transient overvoltage that originates during the atmospheric discharges or switching processes.
- **M** indication specifies a type of construction with removable module.
- **S** indication specifies a version with remote monitoring.

| Туре | | HSA PV 1000/2 M |
|--|--------------------|--------------------------------|
| Test class according to EN 61643-11:2012 and EN 61643-31:2019 | | T2 |
| System | | DC |
| PV system type | | Ungrounded |
| SPD connection type | | U |
| Maximum continuous operating voltage (+/-) | U_{CPV} | 1 000 V DC |
| Maximum continuous operating voltage (±/PE) | U_{CPV} | 500 V DC |
| Max. voltage of PV generator $U_{OCSTC} \le U_{CPV} / 1.2$ | U_{OCSTC} | 830 V |
| Short-circuit current rating | I_{SCPV} | 10 kA |
| Total discharge current (8/20) ±->PE | I_{Total} | 40 kA |
| Maximum discharge current (8/20) | I _{max} | 40 kA |
| Nominal discharge current for class II test (8/20) | I_n | 20 kA |
| Voltage protection level at I _n (+/-) | U_p | < 3.8 kV |
| Voltage protection level at I _n (±/PE) | U_p | < 1.9 kV |
| Response time (+/-) | t_A | < 25 ns |
| Response time (±/PE) | t_A | < 25 ns |
| Housing material | | Polyamid PA6, UL94 V-0 |
| Degree of protection | | IP20 |
| Operating temperature | Э | -40 ÷ 70 °C |
| Humidity range | RH | 5 ÷ 95 % |
| Minimum cross-section of connected Cu conductors according to IEC 61643-32:2017 (doesn't apply to "V" connection) for T2 | S | 2.5 mm² (L+, L-) 6 mm² (PE) |
| Clamp fastening range (solid conductor) | | $2.5 \div 35 \text{ mm}^2$ |
| Clamp fastening range (stranded conductor) | | $2.5 \div 25 \text{ mm}^2$ |
| Tightening moment | | 4 Nm |
| Installation | | On DIN rail 35 mm |
| Modular width | | 2 TE |

Surge arresters T2 for photovoltaic systems




| Туре | | HSA PV 1000/2 M |
|---|---|---|
| Operating position | | Any |
| Product placement environment | | Internal |
| SPD failure mode | | OCFM |
| Signalling at the device | | Optic |
| Importance of local signaling | | OK – green target FAULT – red target |
| Remote signalling | | No |
| Modular design | | Yes |
| Article number of the varistor spare module | | 27 247 |
| Lifetime | | > 100 000 h |
| Designed according to standards | | |
| Requirements and test methods for SPDs for photovoltaic installations | | IEC 61643-31:2018 |
| Safety of Flammability of Plastic Materials | | UL 94 |
| Application standards | | |
| Protection against lightning | | IEC 62305:2010 |
| Selection and application principles for SPDs connected to photovoltaic installations | | IEC 61643-32:2017 |
| Selection and application principles for SPDs connected to photovoltaic installations | | CLC/TS 51643-32:2020 |
| Low-voltage electrical installations - Photovoltaic (PV) systems | | HD 60364-7-712:2016 |
| Ordering, packaging and additional data | | |
| Mass | m | 271 g |
| Mass (including the packaging) | m | 286 g |
| Packaging dimensions (H x W x D) | | 43 x 112 x 87 mm |
| Packaging value | V | 0.42 dm ³ |
| ETIM group | | EG000021 |
| ETIM class | | EC000941 |
| Customs tariff no. | | 85363010 |
| EAN code | | 8590681172131 |
| Art. number | | 27 238 |



The link in the QR code leads to the online presentation of the **HSA PV 1000/2 M**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com**



Application wiring diagram (installation)



Internal diagram

