

## **HSA PV 400 M**

- Surge arresters type T2 intended for photovoltaic systems (PV) at U or Y connection.
- The advantage of the Y connection versus the U connection is the resistance to the earth connection of the working conductors and zero residual (leakage) current through the PE conductor.
- Particular varistor sectors, connected between the terminals L+, Land PE are equipped with internal disconnectors, which are activated when the varistors fail (overheat) and they are able to interrupt the DC current.
- Special construction of the internal disconnector allows installation without a back-up fuse.

- They are installed on the DC side in PV applications without an external LPS or with an external LPS, where the sufficient distance "s" is observed.
- Suitable for all LPL levels.
- Ensure the equipotential bonding of positive and negative busbars of PV systems and the elimination of transient overvoltage that originates during the atmospheric discharges or switching processes.
- **M** indication specifies a type of construction with removable module.
- **S** indication specifies a version with remote monitoring.

| Туре   |                    | HSA PV 400 M   |
|--|--------------------|--|
| Test class according to EN 61643-11:2012 and EN 61643-31:2019  |                    | T2   |
| System   |                    | DC   |
| PV system type   |                    | Ungrounded   |
| SPD connection type  |                    | Υ  |
| Maximum continuous operating voltage (+/-)   | $U_{CPV}$          | 400 V DC   |
| Maximum continuous operating voltage (±/PE)  | $U_{CPV}$          | 400 V DC   |
| Max. voltage of PV generator $U_{OCSTC} \le U_{CPV} / 1.2$   | $U_{\text{OCSTC}}$ | 330 V  |
| Short-circuit current rating   | $I_{SCPV}$         | 10 kA  |
| Total discharge current (8/20) ±->PE   | I <sub>Total</sub> | 40 kA  |
| Maximum discharge current (8/20)   | I <sub>max</sub>   | 40 kA  |
| Nominal discharge current for class II test (8/20)   | In                 | 20 kA  |
| Voltage protection level at I <sub>n</sub> (+/-)   | $U_p$              | < 1.6 kV   |
| Voltage protection level at I <sub>n</sub> (±/PE)  | $U_p$              | < 1.9 kV   |
| Response time (+/-)  | t <sub>A</sub>     | < 25 ns  |
| Response time (±/PE)   | t <sub>A</sub>     | < 100 ns   |
| Housing material   |                    | Polyamid PA6, UL94 V-0                                 |
| Degree of protection   |                    | IP20   |
| Operating temperature  | Э                  | -40 ÷ 70 °C  |
| Humidity range   | RH                 | 5 ÷ 95 %   |
| Minimum cross-section of connected Cu conductors according to IEC 61643-32:2017 (doesn't apply to "V" connection) for T2 | S                  | 2.5 mm <sup>2</sup> (L+, L-)<br>6 mm <sup>2</sup> (PE) |
| Clamp fastening range (solid conductor)  |                    | $2.5 \div 35 \text{ mm}^2$                             |
| Clamp fastening range (stranded conductor)   |                    | $2.5 \div 25 \text{ mm}^2$                             |
| Tightening moment  |                    | 4 Nm   |
| Installation   |                    | On DIN rail 35 mm                                      |
| Modular width  |                    | 3 TE   |

## Surge arresters T2 for photovoltaic systems



| Туре  |   | HSA PV 400 M                            |
|---|---|---|
| Operating position  |   | Any                                     |
| Product placement environment   |   | Internal                                |
| SPD failure mode  |   | OCFM                                    |
| Signalling at the device  |   | Optic                                   |
| Importance of local signaling   |   | OK – green target<br>FAULT – red target |
| Remote signalling   |   | No                                      |
| Modular design  |   | Yes                                     |
| Article number of the varistor spare module   |   | 27 252                                  |
| Article number of the gas discharge tube spare module                                 |   | 30 072                                  |
| Lifetime  |   | > 100 000 h                             |
| Designed according to standards   |   |   |
| Requirements and test methods for SPDs for photovoltaic installations                 |   | IEC 61643-31:2018                       |
| Safety of Flammability of Plastic Materials   |   | UL 94                                   |
| Application standards   |   |   |
| Protection against lightning  |   | IEC 62305:2010                          |
| Selection and application principles for SPDs connected to photovoltaic installations |   | IEC 61643-32:2017                       |
| Selection and application principles for SPDs connected to photovoltaic installations |   | CLC/TS 51643-32:2020                    |
| Low-voltage electrical installations - Photovoltaic (PV) systems                      |   | HD 60364-7-712:2016                     |
| Ordering, packaging and additional data   |   |   |
| Mass  | m | 370 g                                   |
| Mass (including the packaging)  | m | 389 g                                   |
| Packaging dimensions (H x W x D)  |   | 60 x 111 x 87 mm                        |
| Packaging value   | V | 0.58 dm <sup>3</sup>                    |
| ETIM group  |   | EG000021                                |
| ETIM class  |   | EC000941                                |
| Customs tariff no.  |   | 85363010                                |
| EAN code  |   | 8590681187258                           |
| Art. number   |   | 27 228                                  |




**The link in the QR code** leads to the online presentation of the **HSA PV 400 M**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com** 





## Application wiring diagram (installation)



## Internal diagram

